

F

E

D

C

B

A

Catalog Id		Conductor			Stud Size	Dimensions						Color Code	Installation Tooling					Dieless
Without Flared Barrel (Fig-1)	With Flared Barrel (Fig-2)	AWG	Flex Conductor G,H,I,K,M & DLO	Expanded Cod. Range		OD	L	B	A	W	T		Burndy Model - Y35, Y39, Y750, PAT750, PAT750LI	IlSCO ILC-12-N, ILC-12-H-N, ILCB-12		Huskie Model - EP-510C Die Index	Greeniee HK1240	
BT98024	FBT98024	#3/0	#2/0	#3/0 - #2	1/4	0.62 [15.80]	2.36 [60.00]	0.98 [25.00]	1.06 [27.00]	0.90 [22.90]	0.12 [3.20]	Orange	U27RT	ILD-10	ILD - 50	HT41BA	KC12-3/0	Burndy Dieless - PAT444S & PAT4PC834LI.
BT98025	FBT98025				5/16	0.62 [15.80]	2.36 [60.00]	0.98 [25.00]	1.06 [27.00]	0.90 [22.90]	0.12 [3.20]							IlSCO Dieless -IDT-6, IDT-6H, IDTB-6, IDTB-6-LIO, TB-6DF1000-P,IDT-12-N, IVTB-6. Greenlee & NSI Dieless - HK12ID, EK12IDL, N12ID.
BT98026	FBT98026				3/8	0.62 [15.80]	2.36 [60.00]	0.98 [25.00]	1.06 [27.00]	0.90 [22.90]	0.12 [3.20]							
BT98027	FBT98027				1/2	0.62 [15.80]	2.36 [60.00]	0.98 [25.00]	1.06 [27.00]	0.90 [22.90]	0.12 [3.20]							





Fig-1

Fig-2



- Note:
- Manufactured from high strength seamless Copper tubing
 - Color coded die index and crimp marks
 - Electro-Tin plated for corrosion resistance
 - Pre-filled with oxide inhibitor and capped with color coded cap.
 - UL486A/B Listed for Wire Connectors
 - UL Listed and CSA Certified with competitor's compression tools
 - Listed for use with class B & C, flex class G, H, I, K, M & DLO cable

Crimping Instructions

- Select the proper lug or splice connector for the size of cable being installed, ensuring that the size matches the description in the table.
- Strip the insulation from the cable to a length so that the stripped area of the cable can be completely inserted into and fill the barrel of the lug or splice. Carefully strip the insulation from the cable without nicking the strands.
- Clean the stripped portion of the cable to remove oxide films.
- The stripped portion of the cable must be clean and inserted completely into the connector barrel.
- Using the tool and die combination specified for that connector in the table above, install crimps, leaving a space of 1/8 inch minimum between successive crimps.
For Short Barrel Connectors, apply 1 crimp,
For Long Barrel Connectors, apply 2 crimps on the color coded bands

THE INFORMATION CONTAINED WITHIN THIS DOCUMENT IS PROPRIETARY TO OEC AND MAY NOT BE DISCLOSED WITHOUT PRIOR WRITTEN CONSENT

TOLERANCE				
OD	L	B	A	W
±0.20	±1.0	±0.50	±0.50	±1.0

TOLERANCES-UNLESS OTHERWISE SPECIFIED 2 PL. DEC. ±.015 TRUE C.L. ±.015 3 PL. DEC. ±.015 ANGLES ±.015			NAME	DATE	 Usa Inc. 106 Northfield Avenue, Edison, NJ 08837, Phone: +1 732-479-0469 www.oec-americas.com
		DRAWN	R.P.	28.02.25	
		CHECK	S.P.	28.02.25	
		APPROVED	M.K.	28.02.25	
DWG. NO. OC-0003		PROJECTION: FIRST ANGLE 	SIZE A3	TITLE: Copper One Hole Standard Barrel Compression Lug Blank Tang	
MATERIAL Refer Note					
FINISH Refer Note					
				Cat Id. BT98024-BT98027	REV
				DO NOT SCALE DRAWING	SHEET 9 OF 19

F

E

D

C

B

A