

F

E

D

C

B

A

F

E

D

C

B

A

Catalog Id		Conductor			Stud Size	Dimensions						Color Code	Installation Tooling				Dieless	
Without Inspection Window (Fig-1)	With Inspection Window (Fig-2)	AWG	Flex Conductor G,H,I,K,M & DLO	Expanded Cod. Range		OD	L	B	A	W	T		Burndy Model - Y35, Y39, Y750, PAT750, PAT750LI	Ilscos ILC-12-N, ILC-12-H-N, ILCB-12		Huskie Model - EP-510C Die Index		Greenlee HK1240
BT98073	PBT98073	#4/0	#3/0	#4/0 - #1	1/2	0.68 [17.50]	2.80 [71.00]	1.42 [36.00]	1.06 [27.00]	1.00 [25.40]	0.13 [3.40]	Purple	U28RT	ILD-12	ILD - 54	HT41BC	KC12-4/0	Burndy Dieless - PAT444S & PAT4PC834LI.
BT98073A	PBT98073A				3/8	0.68 [17.50]	2.80 [71.00]	1.42 [36.00]	1.06 [27.00]	1.00 [25.40]	0.13 [3.40]							Ilscos Dieless -IDT-6, IDT-6H, IDTB-6, IDTB-6-LIO, TB-6DF1000-P, IDT-12-N, IVTB-6.
BT98073B	PBT98073B				1/4	0.68 [17.50]	2.80 [71.00]	1.42 [36.00]	1.06 [27.00]	1.00 [25.40]	0.15 [3.81]							Greenlee & NSI Dieless - HK12ID, EK12IDL, N12ID.





Fig-1




Fig-2

- Note:
- Manufactured from high strength seamless Copper tubing
 - Color coded die index and crimp marks
 - Electro-Tin plated for corrosion resistance
 - Pre-filled with oxide inhibitor and capped with color coded cap.
 - UL486A/B Listed for Wire Connectors
 - UL Listed and CSA Certified with competitor's compression tools
 - Listed for use with class B & C, flex class G, H, I, K, M & DLO cable

Crimping Instructions

- Select the proper lug or splice connector for the size of cable being installed, ensuring that the size matches the description in the table.
- Strip the insulation from the cable to a length so that the stripped area of the cable can be completely inserted into and fill the barrel of the lug or splice. Carefully strip the insulation from the cable without nicking the strands.
- Clean the stripped portion of the cable to remove oxide films.
- The stripped portion of the cable must be clean and inserted completely into the connector barrel.
- Using the tool and die combination specified for that connector in the table above, install crimps, leaving a space of 1/8 inch minimum between successive crimps.
For Short Barrel Connectors, apply 1 crimp,
For Long Barrel Connectors, apply 2 crimps on the color coded bands

THE INFORMATION CONTAINED WITHIN THIS DOCUMENT IS PROPRIETARY TO OEC AND MAY NOT BE DISCLOSED WITHOUT PRIOR WRITTEN CONSENT

				TOLERANCE				
				OD	L	B	A	W
				±0.20	±1.0	±0.50	±0.50	±1.0
TOLERANCES-UNLESS OTHERWISE SPECIFIED 2 PL. DEC. ±.015 TRUE C.L. ±.015 3 PL. DEC. ±.015 ANGLES ±.015		NAME		DATE		<div> Usa Inc.</div> <div>106 Northfield Avenue, Edison, NJ 08837, Phone: +1 732-479-0469 www.oec-americas.com</div>		
		DRAWN R.P.		03.03.25				
		CHECK S.P.		03.03.25				
		APPROVED M.K.		03.03.25				
DWG. NO. OC-0011		PROJECTION: FIRST ANGLE		  SIZE A3		TITLE: Copper One Hole Long Barrel Compression Lug Blank Tang		
MATERIAL Refer Note								
FINISH Refer Note								
		Cat Id. BT98073 - BT98073B					REV	
		DO NOT SCALE DRAWING					SHEET 10 OF 19	